



## **BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION**

March 19, 2021

**PROJECT: INVITATION FOR BID NO. 21-017 PUMP STATION 4116  
REHABILITATION & FORCE MAIN UPGRADE**

**ADDENDUM: One (1)**

**DUE DATE: Tuesday, April 6, 2021 – 12:00 P.M., NOON EST**

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING  
QUESTIONS:**

- 1) QUESTION: Will the JWSC provide the flow rates and operating pressure for this station?**

**ANSWER: 20 gpm at 49 feet**

- 2) QUESTION: Will the JWSC consider adding time to the completion date of this project due to potential pump/equipment lead times?**

**ANSWER: Additional days may be allotted at the discretion of the JWSC in order to account for any pump or equipment lead times. However, please make sure any potential lead time delays are properly documented by your suppliers and provided to the JWSC. Any extension of schedule will be handled with the selected Contractor at the time of issuance of the Notice to Proceed.**



**All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.**

**ACKNOWLEDGEMENT  
ADDENDUM: ONE (1)**

**DATE:** \_\_\_\_\_

**The above Addendum is hereby acknowledged:**

\_\_\_\_\_  
**(NAME OF BIDDER)**

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Title**