



## **BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION**

March 26, 2021

**PROJECT: INVITATION FOR BID NO. 21-017 PUMP STATION 4116  
REHABILITATION & FORCE MAIN UPGRADE**

**ADDENDUM: Two (2)**

**DUE DATE: Tuesday, April 6, 2021 – 12:00 P.M., NOON EST**

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING  
QUESTIONS:**

- 1) **QUESTION: Would the JWSC consider making Strong Seal High Performance Mix an acceptable product for this project?**

**ANSWER: Yes, Strong Seal High Performance mix will be an acceptable product for this project.**

- 2) **QUESTION: The influent existing SSMH shown on the drawings will be used as the suction manhole for the bypass of the station. What is the surcharge below the rim of the SSMH for pump station 4116?**

**ANSWER: Please reference the record drawing provided with this solicitation package. The surcharge should be no higher than 8' below the rim.**

- 3) **QUESTION: Would the JWSC consider Caprari Submersible Pumps to be considered as an approved equal for this project?**

**ANSWER: No, this pump will not be approved as an equal for this project.**

**4) QUESTION: Would the JWSC be open to bidding polymer concrete as an alternate bid for this project?**

**ANSWER: Polymer concrete will NOT be allowed as an alternate bid for this project.**



**All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.**

**ACKNOWLEDGEMENT  
ADDENDUM: TWO (2)**

**DATE:** \_\_\_\_\_

**The above Addendum is hereby acknowledged:**

\_\_\_\_\_  
**(NAME OF BIDDER)**

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Title**