



BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

February 12, 2024

**PROJECT: INVITATION FOR BID NO. 24-001 HIGHWAY 17 PUMP
STATION REHABILITATION**

ADDENDUM: TWO (2)

DUE DATE: WEDNESDAY, FEBRUARY 21, 2024 - 12:00PM, NOON

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING
CHANGES AND CLARIFICATIONS:**

- 1) **QUESTION: Please indicate the limits of the GAB access road and a depth of GAB. Will geofabric be required under GAB access road?**

ANSWER: The typical depth of GAB is 6" if the soil is soft and this location is low. Minimum is 4". GAB is the entire access road and site shall be covered with a geotextile filter fabric covered with GAB. Treat graveled area with high quality, long lasting EPA approved weed killer.

- 2) **QUESTION: Please provide the two year flood elevation that access road is to be higher than.**

ANSWER: The FEMA flood map for this project area has been posted to the solicitation website, <https://www.bgjwsc.org/invitation-to-bid-24-001-construction-services-for-highway-17-north-mainland-pump-station-re-bid/>

- 3) **QUESTION: Will the existing sign or gas main marker need to be relocated for construction?**

ANSWER: Signs shouldn't need relocation but minor clearing will be needed to install access road.

4) QUESTION: What size gas main runs beside Joann Drive that will have to be crossed? Are there any special requirements to cross the gas main with equipment/materials?

ANSWER: Sizing shall be verified by contractor and crossing shall be coordinated with gas company in regards to separation.

5) QUESTION: Will a one inch water service with RPZ and yard hydrant be required? If so, please indicate on the plans where the connection is to be made and location of RPZ and yard hydrant.

ANSWER: The Contractor shall install RPZ and yard hydrant with service and corp stop for future connection to the main.



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: TWO (2)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title