



## **BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION**

December 19, 2024

**PROJECT:** INVITATION FOR BID NO. 25-002 Construction Services for Exit  
29 Water Production Facility and Elevated Storage Tank

**ADDENDUM:** FOUR (4)

**DUE DATE:** Wednesday, January 8, 2025 - 12:00PM NOON

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING  
CHANGES AND CLARIFICATIONS:**

- 1) **QUESTION:** Specification section 09 96 00, subsection 2.4.A.1.ii refers to only a base coat on the interior of the ground storage tank dome. Please clarify if only a base coat is required.

**ANSWER:** On top of the base Series N218, 2 coats of Series 21 Pota-Pox at 8 mils per coat shall be applied according to manufacturer's application standards. Apply all three layers (1 of N218 and 2 of Pota-Pox) to the dome and 2' down tank walls.



**All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.**

**ACKNOWLEDGEMENT  
ADDENDUM: FOUR (4)**

**DATE:** \_\_\_\_\_

**The above Addendum is hereby acknowledged:**

\_\_\_\_\_  
**(NAME OF BIDDER)**

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Title**